Bill To: SIDERTUL SA DE CV RFC# SID930918KR0 AVENIDA PRESIDENTE MASARYK MEXICO CITY DF

Ship To: 1 SIDERTUL SA DE CV 402 GRAND CENTRAL BLVD MILO DISTRIBUTION CENTER

Order Date:03/09/2011 PO No:4500000579 Mill Order No:3866809 Load No:1401973

CERTIFIED MATERIAL TEST REPORT GERDAU AMERISTEEL

Petersburg Mill GE GERDAU AMERISTEEL 25801 Hofheimer Way Petersburg, VA 23803

Bend Test

Dia. Result

(804) 524-2855

ROA

MX

LAREDO 78045

TXUS

GRADE

Manifest No:2098375

LENGTH PRODUCT

SPECIFICATIONS

11570

W 21 X 101# / W530 X 150

992/572-50

40 FT / 12.192 M

WF BEAMS

ASTM A6-09, A992-06a, A572-07

HEAT NO: 30550630

C Ρ s Mn .09 1.18 .012 .027

Si .24

SIZE

Cu .30

Νi .14

CrMο .12 .025

.016 .001

CHEMICAL ANALYSIS

Sn

Αl

Nb CE .002 .017 .35

PHYSICAL PROPERTIES

Yield Strength		<u>Tensile Strength</u>		Specimen Area		Elongation			
KSI	MPa	KSI	MPa	Sq In	Sq cm	ે	Gage Ler	igth	
56.0	386.1	72.5	499.9	1.073	6.92	27.8	8 In	200 mm	
54.0	372.3	71.9	495.7	1.081	6.97	28.1	8 In	200 mm	

TENSILE TEST RATIOS

YLD/TENS TENS/YLD YLD/TENS TENS/YLD

.77 1.29 .75 1.33

All manufacturing processes of this product, including electric arc MELTING and continuous CASTING, occurred in the U.S.A. CMTR complies with EN 10204 3.1

"I hereby certify that the contents of this report are correct and accurate. All tests and operations performed by this material manufacturer or its sub-contractors, when applicable, are in compliance with the requirements of the material specifications and applicable purchaser designated requirements."

Tom L. Harrington: Quality Assurance Manager

Signed:

Notary Public (if applicable)

Date:

1 of 2 Page: