


Bill To:
SIDERTUL SA DE CV
REC# SID990918KRO
AVENIDA PRESIDENTE MASARYK
MEXICO CITY OF
11570 MX

Ship To: 5
SIDERTUL SA DE CV
402 GRAND CENTRAL BLVD
MILO DISTRIBUTION CENTER
LAREDO TX
78045 US

Order Date: 05/07/2010
PO No: PLESA-TUTL
Mill Order No: 3733364
Load No: 1308020
Manifest No: 2009010

CERTIFIED MATERIAL TEST REPORT
GERDAU AMERISTEEL
Midlothian Mill
300 Ward Road
Midlothian, TX 76065
(972) 775-8241



SPECIFICATIONS
ASTM A6-05a, A992-06a, A572-06

SIZE: W 10 X 26# / W250 X 38.5
GRADE: 992/572-50
LENGTH: 40 FT / 12.192 M
PRODUCT: WF BEAMS

HEAT NO: 11885700

CHEMICAL ANALYSIS

C	Mn	P	S	Si	Cu	Ni	Cr	Mo	Sn	V	Al	Nb	CE
.10	1.00	.012	.020	.26	.26	.10	.20	.108	.010	.003	.003	.016	.35

PHYSICAL PROPERTIES

Yield Strength		Tensile Strength		Specimen Area		Elongation		Bend Test		ROA
KSI	MPa	KSI	MPa	Sq In	Sq cm	%	Gage Length	Dia.	Result	%
51.6	376.5	77.7	535.7	0.398	2.57	25.6	8 In	200 mm		
55.6	383.3	78.9	544.0	0.393	2.54	23.0	8 In	200 mm		

TENSILE TEST RATIOS

YLD/TENS YLD/TENS

.7 .71

All manufacturing processes of this product, including electric arc MELTING and continuous CASTING, occurred in the U.S.A. CMTR complies with EN 10204 3.1

"I hereby certify that the contents of this report are correct and accurate. All tests and operations performed by this material manufacturer or its sub-contractors, when applicable, are in compliance with the requirements of the material specifications and applicable purchaser designated requirements."

Signed: Tom L. Harrington Date: May 27, 2010
Tom L. Harrington: Quality Assurance Manager

Signed: _____ Date: _____
Notary Public (if applicable)

Date: _____
Page: 1 of 1