



AREA: TUBERIA PLACOS Y P. MARCA: ~~XXXXX~~ PROTEC.

CLIENTE: PLESA ANAHUAC Y CIAS., S.A. DE C.V.

O. RT.	NUMERO IDENT	REMISION	PESO KG	PRODUCTO		DIMENSIONES				COMPOSICION QUIMICA					TAMAÑO		NORMA
				MATERIAL	TIPO	ACABADO	CAL	ANCHO	LARGO	DIAMETRO	% C	% Mn	% P	% S	% AS	MUESTRA	
	0883413	124003126	SEGUN	VIGA	IPR	-	14 X	079KG/M	12.20m	-	.15	1.01	.025	.006	-	-	ASTM-A-36
	0874938	124003126	REMISION	VIGA	IPR	-	14 X	079KG/M	12.20m	-	.19	1.13	.016	.007	-	-	ASTM-A-36
	0874937	124003127		VIGA	IPR	-	14 X	079KG/M	12.20m	-	.10	1.37	.019	.013	-	-	ASTM-A-36
	0874938	124003127		VIGA	IPR	-	14 X	079KG/M	12.20m	-	.19	1.13	.016	.007	-	-	ASTM-A-36

No. PART.	PROPIEDADES MECANICAS			APARIENCIA			OBSERVACIONES
	Res. Teni6n	% ELONG.	L6mite El6stico	COPA Erichsen	Dureza RB	OLIMP	
1	498MPA	32.0	370MPA	-	-	-	PROV GERDAU CERT 3/7
2	628MPA	26.0	420MPA	-	-	-	PROV GERDAU CERT 3/7
3	522MPA	29.5	398MPA	-	-	-	PROV GERDAU CERT 3/7
4	528MPA	26.0	420MPA	-	-	-	PROV GERDAU CERT 3/7



Hora de impresi6n: 11:13 a.m.

ASEGURAMIENTO DE CALIDAD: Enrique Vel6zquez Mart6nez

FIRMA