

Bill To:
 SIDERTUL SA DE CV
 RFC# SID930918KRO
 AVENIDA PRESIDENTE MASARYK
 MEXICO CITY DF
 11570 MX

Ship To: 5
 SIDERTUL SA DE CV
 402 GRAND CENTRAL BLVD
 MILO DISTRIBUTION CENTER
 LAREDO TX
 78045 US

Order Date: 05/07/2010
 PO No: PLESA-TUTL
 Mill Order No: 3733367
 Load No: 1308899
 Manifest No: 2009261

CERTIFIED



SPECIFICATIONS
 ASTM A6-05a, A992-06a, A572-06

SIZE: W 12 X 40# / W310 X 60
 GRADE: 992/572-50
 LENGTH: 40 FT / 12.192 M

HEAT NO: 22543960


CHEMICAL ANALYSIS													
C	Mn	P	S	Si	Cu	Ni	Cr	Mo	Sn	V	Al	Nb	CE
.09	.93	.016	.031	.21	.36	.09	.15	.030	.011	.001	.003	.021	.31

Yield Strength				Tensile Strength				Specimen Area		Elongation	
KSI	MPa	KSI	MPa	Sq In	Sq cm	%	Gage Length				
54.0	372.3	72.0	496.4	0.724	4.67	25.9	8 In 200 mm				
56.3	388.2	72.7	501.2	0.746	4.81	24.7	8 In 200 mm				

TENSILE TEST RATIOS
 YLD/TENS YLD/TENS
 .75 .77

All manufacturing processes of this product, including electric arc MELTING and continuous CASTING CMTR complies with EN 10204 3.1

"I hereby certify that the contents of this report are correct and accurate. All tests and operations performed by the material manufacturer or its sub-contractors, when applicable, are in compliance with the requirements and applicable purchaser designated requirements."

Signed:  Date: May 28, 2010
 Tom L. Harrington: Quality Assurance Manager

Signed: _____
 Notary Public (if applicable)