Bill To: PLESA ANAHUAC Y CIAS SA DE CV PLESA ANAHUAC Y CIAS SA DE CV AV VALLE DE LAS ALAMEDAS NO 66-0 COL SAN FRANCISCO MEXICO CITY/DEL. TUL! DF MX 54940

Ship To: 1 302 OUIVIRA DR

PAN AMERICAN BUSINESS PARK ΤX LAREDO US 78045

Order Date: 08/13/2009 PO No:6858

Mill Order No:3637217 Load No:1275162 Manifest No:1976950

CERTIFIED MATERIAL TEST REPORT GERDAU AMERISTEEL

Midlothian Mill 300 Ward Road Midlothian, TX 76065

GERDAU AMERISTEEL

(972)775-8241

SPECIFICATIONS

.08

GRADE SIZE 992/572-50 W 12 X 26# / W310 X 38.7

.09

. 34

.09

LENGTH 40 FT / 12,192 M PRODUCT WE BEAMS

ASTM A6-05a, A992-06a, A572-06

.82

.008

.035

HEAT NO: 22519600 S Νi CrC Ρ Si Cu Mn

.21

CHEMICAL ANALYSIS Mo Sn Al Nb CE .003 .27 .001 .016 .021 .009

PHYSICAL PROPERTIES

Yield Strength		Tensile Strength		Specimen Area		Elongation		Bend Test	ROA	
KSI	MPa	KSI	MPa	Sq In	Sq cm	ક્ર	Gage Ler	ngth	Dia. Result	8
55.8	384.7	74.2	511.6	0.520	3.35	21.8	8 In	200 mm		
57.0	393.0	75.8	522.6	0.512	3.30	23.1	8 In	200 mm	•	

TENSILE TEST RATIOS

YLD/TENS

.75



All manufacturing processes of this product, including electric arc MELTING and continuous CASTING, occurred in the U.S.A. CMTR complies with EN 10204 3.1

"I hereby certify that the contents of this report are correct and accurate. All tests and operations performed by this material manufacturer or its sub-contractors, when applicable, are in compliance with the requirements of the material specifications and applicable purchaser designated requirements."

Tom L. Harrington: Quality Assurance Manager

Signed:

Notary Public (if applicable)

Date:

2 of Page: