WALWORTH
Industrial de Válvulas, S.A. de C.V.

Av. Industria 16,
Fraccionamiento Industrial El Trébol
Tepotzotlán, Edo, de México, 54600.

No. DE SERIE : W02G1200
FECHA : 13 SEP 02

ASEGURAMIENTO DE CALIDAD
CERTIFICADO DE CUMPLIMIENTO

CERTIFICAMOS QUE EL PRODUCTO LISTADO ABAJO FUE DISEÑADO, FABRICADO Y PROBADO DE ACUERDO CON NUESTRO SISTEMA DE CALIDAD Y CON REQUISITOS ESTABLECIDOS EN UNO O MAS DE LOS SIGUIENTES STANDARES:

API 6D	- PIPELINE VALVES - GATE,PLUG,BALL AND CHECK
API 600	- STEEL GATE VALVES - FLANGED AND BUTT-WELDING ENDS
API 598	- VALVE INSPECTION AND TESTING
API 599	- METAL PLUG VALVES - FLANGED AND WELDING ENDS
ANSI B16.10	- FACE TO FACE AND END TO END DIMENSIONS OF VALVES
ANSI B16.34	- VALVES - FLANGED,THREADED, AND WELDING ENDS
MSS-SP61	- PRESSURE TESTING OF STEEL VALVES

No. PARTE: 82610P

DESCRIPCION: 2" FIG. 5275 F UT WCB, API TRIM No. 8 SPECIFICATION 83000
CAST STEEL GLOBE VALVE

PRUEBAS DE PRESION	CASCO	SELLO POST.	1ER LADO	2DO LADO
HIDROSTATICA (PSI)	450	450	315	N A
NEUMATICA (PSI)			90	N A

PARTE	No. DE COLADA	MATERIAL (ASTM)	C	Mn	P	S	Si	Ni	Cr	Mo	Cu	V	W	TENS KPSI CVN@	ELAST KPSI 1ST	ELG % 2ND	RED % 3RD	BHN AVG
			COMPOSICION QUIMICA											PROPIEDADES MECANICAS				
BODY	2009A038	A 216 WCB	0.210	0.990	0.025	0.013	0.520	0.110	0.200	0.070	0.051	0.002		81.98	50.54	26.0	56.0	163
BONNET-COVER	02J349	A 216 WCB	0.200	0.890	0.028	0.017	0.460	0.090	0.190	0.060	0.034	0.003		74.12	49.41	27.0	56.0	156
WEDGE-DISC-PLUG	663-02	A 276 410	0.148	0.640	0.024	0.010	0.460	0.200	12.750		0.050			87.75	71.36	24.0	58.0	170

CERTIFICADO POR: _____
ASEGURAMIENTO DE CALIDAD

FAC10-22 REV. "0"