WALWORTH

Industrial de Válvulas, S.A. de C.V.

Av. Industria 16,
Fraccionamiento Industrial El Trébol
Tepotzotlán, Edo, de México, 54600.

No. DE SERIE : W02C1201
FECHA : 13 SEP 02

ASEGURAMIENTO DE CALIDAD
CERTIFICADO DE CUMPLIMIENTO

CERTIFICAMOS QUE EL PRODUCTO LISTADO ABAJO FUE DISEÑADO, FABRICADO Y PROBADO DE ACUERDO CON NUESTRO SISTEMA DE CALIDAD Y CON REQUISITOS ESTABLECIDOS EN UNO O MAS DE LOS SIGUIENTES STANDARES:

API 6D	- PIPELINE VALVES - GATE,PLUG,BALL AND CHECK
API 600	- STEEL GATE VALVES - FLANGED AND BUTT-WELDING ENDS
API 598	- VALVE INSPECTION AND TESTING
API 599	- METAL PLUG VALVES - FLANGED AND WELDING ENDS
ANSI B16.10	- FACE TO FACE AND END TO END DIMENSIONS OF VALVES
ANSI B16.34	- VALVES - FLANGED,THREADED, AND WELDING ENDS
MSS-SP61	- PRESSURE TESTING OF STEEL VALVES

No. PARTE: 82610P

DESCRIPCION: 2" FIG. 5275 F UT WCB, API TRIM No. 8 SPECIFICATION 83000
CAST STEEL GLOBE VALVE

PRUEBAS DE PRESION	CASCO	SELLO POST.	1ER LADO	2DO LADO
HIDROSTATICA (PSI)	450	450	315	N A
NEUMATICA (PSI)			80	N A

PARTE	No. DE COLADA	MATERIAL (ASTM)	C	Mn	P	S	Si	Ni	Cr	Mo	Cu	V	W	TENS KPSI CVN@	ELAST KPSI 1ST	ELG % 2ND	RED % 3RD	BHN AVG
		COMPOSICION QUIMICA												PROPIEDADES MECANICAS				
BODY	2809A029	A 216 WCB	0.230	0.850	0.018	0.017	0.550	0.080	0.170	0.050	0.031	0.002		79.73	47.17	29.0	56.0	163
BONNET-COVER	02J390	A 216 WCB	0.210	0.860	0.026	0.019	0.410	0.080	0.180	0.060	0.045	0.003		73.00	46.04	26.0	54.0	156
WEDGE-DISC-PLUG	663-02	A 276 410	0.148	0.640	0.024	0.010	0.460	0.200	12.750		0.050			87.75	71.36	24.0	58.0	170

CERTIFICADO POR: _____
ASEGURAMIENTO DE CALIDAD

FAC10-22 REV. "0"