WALWORTH
Industrial de Válvulas, S.A. de C.V.

Av. Industria 16,
Fraccionamiento Industrial El Trébol
Tepotzotlán, Edo, de México, 54600.

No. DE SERIE : V02R1485
FECHA : 09 JUL 02

ASEGURAMIENTO DE CALIDAD
CERTIFICADO DE CUMPLIMIENTO

CERTIFICAMOS QUE EL PRODUCTO LISTADO ABAJO FUE DISEÑADO, FABRICADO Y PROBADO DE ACUERDO CON NUESTRO SISTEMA DE CALIDAD Y CON REQUISITOS ESTABLECIDOS EN UNO O MAS DE LOS SIGUIENTES STANDARES:

API 6D	- PIPELINE VALVES - GATE,PLUG,BALL AND CHECK
API 600	- STEEL GATE VALVES - FLANGED AND BUTT-WELDING ENDS
API 598	- VALVE INSPECTION AND TESTING
API 599	- METAL PLUG VALVES - FLANGED AND WELDING ENDS
ANSI B16.10	- FACE TO FACE AND END TO END DIMENSIONS OF VALVES
ANSI B16.34	- VALVES - FLANGED,THREADED, AND WELDING ENDS
MSS-SP61	- PRESSURE TESTING OF STEEL VALVES

No. PARTE: 75711P

DESCRIPCION: 3" FIG. 5341 F UT WCB, API TRIM No. 8
CAST STEEL SWING CHECK VALVE

SPECIFICATION 82000

PRUEBAS DE PRESION	CASCO	SELLO POST.	1ER LADO	2DO LADO
HIDROSTATICA (PSI)	450	N A	N A	315
NEUMATICA (PSI)			N A	N A

		COMPOSICION QUIMICA													PROPIEDADES MECANICAS				
PARTE	No. DE COLADA	MATERIAL (ASTM)	C	Mn	P	S	Si	Ni	Cr	Mo	Cu	V	W		TENS KPSI CVN@	ELAST KPSI 1ST	ELG % 2ND	RED % 3RD	BHN AVG
BODY	3067A074	A 216 WCB	0.210	0.920	0.014	0.011	0.480	0.100	0.160	0.030	0.029	0.001			78.61	48.29	24.0	54.0	156
BONNET-COVER	3024A069	A 216 WCB	0.210	0.960	0.020	0.014	0.570	0.130	0.210	0.040	0.035	0.002			83.10	49.41	25.0	48.0	163
WEDGE-DISC-PLUG	240-02	A 276 410	0.121	0.924	0.020	0.004	0.734	0.237	12.729	0.038					97.00	75.00	35.0	50.0	207

CERTIFICADO POR: Jorge Soto
ASEGURAMIENTO DE CALIDAD

FAC10-22 REV. "0"